

**REMARKS**

Claims 1-16 and 18-19 were previously pending in the application. By the Amendment, Claims 1, 12 and 19 are currently amended, Claim 15 is canceled without prejudice, and Claims 1-11, 13-14, 16 and 18 remain unchanged.

The Examiner objected to the drawings for failing to show every feature of the invention and stated that “the mesh as claimed in claim 14, must be shown or the feature(s) canceled from the claim(s).” Applicants assume the Examiner was referring to Claim 15, which recites the “a mesh”, not Claim 14. Therefore, Applicants have canceled Claim 15 and request that the objection to the drawings be withdrawn.

The claims stand rejected under the cited prior art of record. Specifically, Claims 1-5 and 7-13 were rejected under 35 USC §102(b) as being anticipated by Manuel (US 3,827,262). Claims 14-16 and 19 were rejected under 35 USC §103(a) as being unpatentable over Manuel in view of Bahnsen (US 3,499,176). Claim 6 was rejected under 35 USC §103(a) as being unpatentable over Manuel in view of Smull (US 3,352,723). Claim 18 was rejected under 35 USC §103(a) as being unpatentable over Manuel in view of Smith (US 2,732,701).

Independent Claim 1 recites a washing machine, comprising: a housing; a conveyor disposed in said housing for moving laundry goods in a circulation along a closed looped path in said housing; a suds application device at least partially disposed in said housing for applying suds to the laundry goods; and a cleaning device at least partially disposed in said housing for removing dissolved dirt from the laundry goods; and an integrated smoothing and pressing device for smoothing and pressing the laundry goods.

Independent Claim 12 recites a washing machine, comprising: a housing; a conveyor disposed in said housing for moving laundry goods in a circulation along a closed looped path in said housing; a suds application device at least partially disposed in said housing for applying suds to the laundry goods; and a cleaning device at least partially disposed in said housing for removing dissolved dirt from the laundry goods; and a pre-dehumidification device disposed in a given area of said circulation for at least partially removing liquid from the laundry goods, said pre-dehumidification device having a pair of rollers through which the laundry goods are pulled.

Independent Claim 19 recites A washing machine, comprising: a housing; means for transporting laundry goods in a circulation along a closed looped path in said housing; means for applying suds to the laundry goods; and means for removing dissolved dirt from the laundry goods; means for at least partially removing liquid from the laundry goods disposed in a given area of said circulation, said means for at least partially removing liquid from the laundry goods having an air supplying device for applying compressed air to the laundry goods; and said means for at least partially removing liquid from the laundry goods having a mesh for receiving thereat the laundry goods while said air supplying device applies the compressed air.

Claims 1, 12 and 19 are presented together because they all recite the similar limitation of “circulation along a closed looped path in said housing.”

Manuel discloses a washing system having a conveyor (14) carrying garments through a soak station (16), multiple washing stations (18, 20), squeeze roll pair (22), rinse station (24), and squeeze roll pair (28). In Manuel, the garments travel along a linear path entering through one end and exiting from the opposite end.

Manuel does not disclose, among other things, “a conveyor disposed in said housing for moving laundry goods in a circulation along a closed looped path in said housing,” as recited in Claims 1 and 12. In addition, Manuel does not disclose, among other things, “means for transporting laundry goods in a circulation along a closed looped path in said housing,” as recited in Claim 19. Rather, Manuel discloses the conveyor moving laundry goods in a linear path having two terminal ends. The Examiner has acknowledged this difference, but has rejected the claim based on interpretation of the term “circulation”. The Examiner cited a dictionary definition for “circulation” as meaning “the transmission or passage of anything from place to place.” The Examiner then suggested using the term “recirculation” to define over the prior art.

Applicants believe the term “circulation” by itself was sufficient to define over the prior art, including Manuel. Regardless, Applicants have amended Claims 1, 12 and 19 to recite “circulation along a closed looped path” to more clearly recite the claimed invention. Manuel does not disclose “a conveyor disposed in said housing for moving laundry goods in a circulation along a closed looped path in said housing.”

Applicants acknowledge that Claims 1, 12 and 19 are being amended after a Final Office action, under 37 CFR §1.116. These amendments were not made previously due to Examiner's new interpretation of the term "circulation." As suggested by the Examiner, amending the claim to recite the term "recirculation" would more precisely define the invention and avoid the broader interpretation of the term "circulation". Applicants instead prefer the claim language of "circulation in a closed loop" to define the claimed invention and have amended Claims 1, 12 and 19 accordingly to include this limitation. Therefore, these amendments are being made in response to the Examiner's suggestion in the Office action.

These amendments were not presented earlier because Applicants believed "circulation" adequately defined over the prior art. As stated by the Examiner in the Final Office action, the indication of previously allowable claims was withdrawn after a new broader reading of the Manuel patent. The Examiner also made this action Final, so this is the Applicants' first opportunity to respond to these rejections based on new broader readings and interpretations. Applicants believe these amendments are necessary to properly respond to the new broader readings and interpretations and also believe these amendments will place the application in condition for allowance. Applicants also believe this final rejection was issued prematurely because a clear issue had not been established between the Examiner and the Applicants, as recommended in MPEP 706.07. Finally, these amendments do not necessitate any additional searching of the prior art. Therefore, Applicants respectfully request entry of these amendments and allowance of Claims 1, 12 and 19.

For these and other reasons, Manuel does not disclose the subject matter defined by independent Claims 1, 12 and 19. Therefore, Claims 1, 12 and 19 are allowable. Claims 2-11, 16 and 18 depend from Claim 1 and are allowable for the same reasons and also because they recite additional patentable subject matter.

Independent Claim 13 recites A washing machine, comprising: a housing; a conveyor disposed in said housing for moving laundry goods in a circulation in said housing; a suds application device at least partially disposed in said housing for applying suds to the laundry goods; and a cleaning device at least partially disposed in said housing for removing dissolved dirt from the laundry goods; and a pre-dehumidification

device disposed in a given area of said circulation for at least partially removing liquid from the laundry goods; said pre-dehumidification device having: an absorbable fleece; and at least one roller for pressing the laundry goods against said fleece; and said fleece being, at least during pressing, substantially guided parallel to a motion of the respective laundry goods.

Manuel does not disclose, among other things, a pre-dehumidification device having an absorbable fleece, as recited in Claim 13. The Examiner contends that the squeeze rolls of Manuel disclose the “absorbable fleece” of Claim 13 and has cited Col. 3, lines 66-67 of Manuel as support. The squeeze rolls of Manuel are not absorbable, are not a fleece material, and are not the equivalent of an absorbable fleece.

Manuel states that the sponge rubber rolls are made from a material known as Armaflex® insulation, used for insulating refrigeration pipes. Applicants have enclosed additional information on the rubber material known as Armaflex® and made by the Armacell company in Appendix A of this Amendment. The enclosed description of Armaflex® explains that the material is resistant to moisture. The material is not absorbable and is actually designed to be impermeable to water. The material is intended as thermal insulation, primarily for refrigeration or cooling tubes, and is designed to resist moisture formed through condensation. This material has the opposite physical properties of the “absorbable” fleece recited in Claim 13. Therefore, Manuel does not disclose an absorbable fleece and in fact teaches away from the claimed invention by stating that a material that resists moisture should be used for the sponge rubber rolls.

For these and other reasons, Manuel does not disclose the subject matter defined by independent Claim 13. Therefore, Claim 13 is allowable. Claim 14 depends from Claim 13 and is allowable for the same reasons and also because they recite additional patentable subject matter.

**CONCLUSION**

In view of the above, entry of the present Amendment and allowance of Claims 1-14, 16 and 18-19 are respectfully requested. If the Examiner has any questions regarding this amendment, the Examiner is requested to contact the undersigned. If an extension of time for this paper is required, petition for extension is herewith made. Please note that Applicants have changed representation and are now represented by new counsel. The formal Revocation of Power of Attorney / New Power of Attorney and Change of Correspondence Address documents will be forthcoming.

Craig J. Loest

Name of Attorney Signing under 37 CFR 1.34

Respectfully submitted,

A handwritten signature in black ink, appearing to read 'Craig J. Loest', with a long horizontal stroke extending to the right.

Craig J. Loest


Registration No. 48,557

August 15, 2005

BSH Home Appliances Corp.  
100 Bosch Blvd  
New Bern, NC 28562  
252-672-7930  
email: [craig.loest@bshg.com](mailto:craig.loest@bshg.com)

## BEST AVAILABLE COPY

### API/ARMAFLEX 25/50 RATED TUBES/SHEETS/ROLLS - New Code Compliant 1-1/2"



- Physical Properties
  - Tubes
  - Sheets & Rolls
- Product Range
- Material Safety Data Sheet
- Master Insulation Guide
- Installation Guide
- Color Data Sheet



### General Product information

- Conforms to NFPA 90A and 90B
- Improved condensation protection for severe design conditions
- Conforms to ASTM C 534, Type I and II - Grade 1

### Description

AP/Armaflex Insulation is a flexible elastomeric thermal insulation and black in color.

The expanded closed-cell structure of AP/Armaflex makes it an efficient insulation. It is manufactured without the use of CFC's, HFC's or HCFC's. It is also formaldehyde free, low VOCs, fiber free, dust free and resists mold and mildew.

### Uses

AP/Armaflex Insulation is used to retard heat gain and control condensation drip from chilled water and refrigeration systems. It also efficiently reduces heat flow on hot systems. The recommended temperature usage range for AP/Armaflex Insulation is -70°F to +220°F (-57°C to +105°C).

For use on cold pipes, AP/Armaflex thicknesses have been calculated to control condensation on the insulation outer surface, as shown in the table of thickness recommendations.

### Factory Mutual Approvals System

AP/Armaflex Insulation, in thicknesses through 1-1/2" (38mm) has a flame-spread index of less than 25 and a smoke-developed index of less than 50 as tested by ASTM E 84, "Method of Test for Surface Burning Characteristics of Building Materials."

**Note:** Numerical flammability ratings alone may not define the performance of products under actual fire conditions. They are provided only for use in the selection of products to meet limits specified.

### Resistance to Moisture Vapor Flow

The closed-cell structure of AP/Armaflex Insulation effectively prevents moisture from wicking and makes it an efficient insulation. AP/Armaflex normally requires no supplemental vapor-retarder protection. Additional vapor-retarder protection may be necessary for AP/Armaflex when installed on very-low-temperature piping or where exposed to continually high humidity conditions.



All data is valid for the application of our products in USA and Canada.

All statements and technical information are based on results obtained under typical conditions. It is the responsibility of the recipient to verify with us that the information is appropriate for the

## BEST AVAILABLE COPY

AP/ARMAFLEX 25/50 RATED  
TUBES/SHEETS/ROLLS -  
New Code Compliant 1-1/2"

## Physical Properties - Tubes




Thermal conductivity, BTU • in./h • ft <sup>2</sup> • °F (W/mK) 75°F mean temp (24°C)	0.28 (0.040)	ASTM C 177
Water vapor permeability, perm-in. [Kg/(s • m • Pa)]	0.08 (1.16 x 10 <sup>-13</sup> )	ASTM E 96 Procedure A
Flame spread and smoke developed index	25/50	ASTM E 84
Mold growth Fungi resistance Bacterial resistance	UL 181 ASTM G 21/C 1338 ASTM G 22	Meets requirements Meets requirements Meets requirements
Water absorption, % by volume	0.2	ASTM C 209
Upper use limit	220°F (105°C)  <i>Note:</i> On the heating cycle, AP/Armaflex Pipe Insulation will withstand temperatures as high as 220°F (105°C). 520 or 520 BLV Adhesive may be used with pipe insulation applications up to 220°F (105°C).	
Lower use limit	-70°F (-57°C)*  <i>Note:</i> At -20°F (-29°C), flexible AP/Armaflex Insulation becomes hard and, as temperatures drop below -20°F (-29°C), will be increasingly brittle; however, this hardening characteristic does not affect thermal efficiency or water vapor permeability. * For applications of -40°F to -70°F (-40°C to -57°C), contact Armacell.	
Ozone resistance	Excellent	
Sizes Wall thickness Inside diameter, tubular form Length of sections, feet, tubular form	1-1/2" (38mm) 1-1/2" IPS to 4" IPS (48mm to 114mm) 3 (0.9m)	
Density, typical range	3.0 - 6.0 lbs./ft. <sup>3</sup>	ASTM D 1622 or D 1667

BEST AVAILABLE COPY



THE MAKERS OF  
**Armaflex®**



**Armaflex®**

## **Master Insulation Guide Specification for Mechanical Systems**

- AP Armaflex® Pipe Insulation
- AP Armaflex W Pipe Insulation
- AP Armaflex SS Pipe Insulation
- AP Armaflex Sheet and Roll Insulation
- AP Armaflex SA Sheet and Roll Insulation
- ArmaTuff Laminated Sheets and Rolls

- HT Armaflex Pipe Insulation
- HT Armaflex Roll Insulation
- NH Armaflex Pipe Insulation
- NH Armaflex Sheet and Roll Insulation
- Armafix (IPH and NPH) Insulation Pipe Hangers



# ***Master Insulation Guide Specification For Mechanical Systems***

---

## **Part 1 – General**

### **1.01 Scope of Work:**

- A. Provide piping, ductwork and equipment insulation as specified below.

### **1.02 Definitions:**

- A. Cold Piping/Surfaces: Pipes or surfaces where the normal operating temperature is 60°F or lower.
- B. Third Party Supervision Testing: Verification testing by a nationally recognized independent testing organization that will conduct sampling of the product through to simulated end use testing.
- C. Thermal Conductivity: The amount of heat in Btus transferred in one hour through one square foot of homogeneous material one inch in thickness when there is a temperature difference of 1°F.
- D. Compression Fit Method: To allow for expansion and contraction of sheet and roll insulation, leave a 1/2" -wide uncoated border at the butt-edge seams on the surface to be insulated and the insulation surface. Overlap the insulation 1/4" at the butt-edge and compress the edges into place. Apply adhesive to the butt-edges of the insulation.

### **1.03 Quality Assurance:**

- A. Material shall be delivered in nonbroken, factory furnished packaging and stored in a clean, dry indoor space that provides protection against the weather.
- B. Insulation shall be applied by qualified personnel skilled in this trade.
- C. Progressive testing of the systems to be insulated shall have been completed, inspected and approved by the owners' representative before the insulation is applied.
- D. Insulation shall not be applied until all surfaces are clean; dry, and free of dirt, dust, grease, frost, moisture, and other extraneous elements.
- E. Work shall be performed at the temperatures recommended by the product manufacturer.

---

## **Part 2 – Products**

### **2.01 Elastomeric Insulation:**

**2.01.1 Acceptable Manufacturers** – These specifications are based on products and data of Armacell and designate the type and quality of work intended under this section. Products of other manufacturers proposed as equivalent must be submitted for written approval by the specifying engineer ten days prior to the bid date. Supporting technical data, samples, published specifications and the like must be submitted for comparison. The contractor should warrant that proposed substitutions, if accepted, will provide performance equal to the materials specified herein.

- A. Insulation material shall be a flexible, closed-cell elastomeric insulation in tubular or sheet form: AP Armaflex, AP Armaflex W, AP Armaflex SS, or AP Armaflex SA. This product meets the requirements as defined in ASTM C 534, "Specification for preformed elastomeric cellular thermal insulation in sheet and tubular form."
- B. Insulation materials shall have a closed-cell structure to prevent moisture from wicking which makes it an efficient insulation.
- C. Insulation material shall be manufactured without the use of CFC's, HFC's or HCFC's. It is also formaldehyde free, low VOC's, fiber free, dust free and resists mold and mildew.
- D. Materials shall have a flame spread index of less than 25 and a smoke-developed index of less than 50 when tested in accordance with ASTM E 84, latest revision. In addition, the product, when tested, shall not melt or drip flaming particles, the flame shall not be progressive and all materials shall pass simulated end-use fire tests.
- E. Materials shall have a maximum thermal conductivity of 0.27 Btu-in./h-ft<sup>2</sup>-°F at a 75°F mean temperature when tested in accordance with ASTM C 177 or ASTM C 518, latest revisions.
- F. Materials shall have a maximum water vapor transmission of 0.08 perm-inches when tested in accordance with ASTM E 96, Procedure A, latest revision.
- G. The material shall be manufactured under an independent third party supervision testing program covering the properties of fire performance, thermal conductivity and water vapor transmission.

## **2.02 Special Elastomeric Insulations – High Temperature and Nonhalogen**

**2.02.1 Acceptable Manufacturers** – These specifications are based on products and data of Armacell and designate the type and quality of work intended under this section. Products of other manufacturers proposed as equivalent must be submitted for written approval by the specifying engineer ten days prior to the bid date. Supporting technical data, samples, published specifications, and related documentation must be submitted for comparison. The contractor should warrant that proposed substitutions, if accepted, will provide performance equal to the materials specified herein.

- A. Insulation material shall be a flexible, closed-cell elastomeric insulation in tubular or sheet form: HT Armaflex or NH Armaflex.
- B. Materials shall have a flame spread index of less than 30 and a smoke developed index of less than 200 when tested in accordance with ASTM E 84, latest revision. In addition, the product, when tested, shall not melt or drip flaming particles, and the flame shall not be progressive.
- C. HT Armaflex shall have a maximum thermal conductivity of 0.30 Btu-in./h-ft<sup>2</sup>-°F at a 75°F mean temperature when tested in accordance with ASTM C 177 or ASTM C 518, latest revisions. NH Armaflex shall have a maximum thermal conductivity of 0.275 Btu-in./h-ft<sup>2</sup>-°F at a 75°F mean temperature when tested in accordance with ASTM C 177 or ASTM C 518, latest revisions.
- D. HT Armaflex and NH Armaflex shall have a maximum water vapor transmission of 0.05 perm-inches when tested in accordance with ASTM E 96, Procedure A, latest revision.

## **2.03 Adhesives and Finishes**

- A. Adhesive shall be the insulation manufacturer's recommended contact adhesive: Armaflex 520, Armaflex 520 BLV or Armaflex HT 625 Adhesive.
- B. Insulation finish shall be the insulation manufacturer's recommended finish: WB Armaflex Finish.
- C. Accessories such as adhesives, mastics and cements shall have the same properties as listed above and shall not detract from any of the system ratings as specified above.

---

## Part 3 – Installation

### 3.01 Piping:

- A. Install pipe insulation by slitting tubular sections and applying onto piping or tubing. Alternately, whenever possible, slide unslit sections over the open ends of piping or tubing. All seams and butt joints shall be adhered and sealed using Armaflex 520 or 520 BLV Adhesive. When using AP Armaflex SS, only the butt joints shall be adhered using Armaflex 520 or 520 BLV Adhesive. Armaflex HT 625 Adhesive shall be used with HT Armaflex.
- B. Insulation shall be pushed onto the pipe, never pulled. Stretching of insulation may result in open seams and joints.
- C. Tape the ends of the copper tubing before slipping the Armaflex insulation over the new pipes to prevent dust from entering the pipe.
- D. All edges shall be clean cut. Rough or jagged edges of the insulation shall not be permitted. Proper tools such as sharp non-serrated knives must be used.
- E. On cold piping, insulation shall be adhered directly to the piping at the high end of the run using a two-inch strip of Armaflex 520 or 520 BLV Adhesive on the ID of the insulation and on the pipe. All exposed end cuts of the insulation shall be coated with Armaflex 520 or 520 BLV Adhesive. All penetrations through the insulation and termination points must be adhered to the substrate to prevent condensation migration.
- F. Sheet insulation shall be used on all pipes larger than 6" IPS. Insulation shall not be stretched around the pipe. On pipes larger than 12" IPS, adhere insulation directly to the pipe on the lower 1/3 of the pipe. On pipes greater than 24" IPS, complete adhesion is recommended.
- G. Seams shall be staggered when applying multiple layers of insulation.

### 3.02 Valves, Flanges and Fittings:

- A. All fittings shall be insulated with the same insulation thickness as the adjacent piping. All seams and mitered joints shall be adhered with Armaflex 520 or 520 BLV Adhesive. Screwed fittings shall be sleeved and adhered with a minimum 1" overlap onto the adjacent insulation. Armaflex HT 625 Adhesive shall be used with HT Armaflex.
- B. Valves, flanges, strainers, and Victaulic couplings shall be insulated using Armaflex donuts that shall then be covered with sheet or oversized tubular insulation.

### 3.03 Hangers:

- A. Support piping system using high density inserts with sufficient compressive strength. The pipe support insulation shall be elastomeric foam with the same or greater thickness than the pipe insulation. All joints shall be sealed with Armaflex 520 or 520 BLV adhesive.
- B. Standard and split hangers -- Piping supported by ring hangers shall have hangers insulated with the same insulation thickness as the adjacent pipe. All seams and butt joints shall be sealed with Armaflex 520 or 520 BLV Adhesive. Armaflex HT 625 Adhesive shall be used with HT Armaflex. Ring hangers may be sleeved using oversized tubular insulation. On cold piping, insulation shall extend up the hanger rod a distance equal to four times the insulation thickness. Insulation tape may be used to a thickness equal to the adjacent insulation thickness.

- C. Clevis hangers or other pipe support systems -- Saddles shall be installed under all insulated lines at unistrut clamps, clevis hangers, or locations where the insulation may be compressed due to the weight of the pipe. All piping shall have wooden dowels or blocks of a thickness equal to the insulation inserted and adhered to the insulation between the pipe and the saddle.

It is highly recommended for continuous insulation protection to use hanger sizes equal to the outer diameter of the pipe plus insulation thickness.

- D. Armafix IPH or Armafix NPH can be used to prevent compression of insulation at standard split, clevis hangers or other pipe support systems. To minimize the movement of Armafix, it is recommended that a pair of non-skid pads be adhered to the clamps. In addition, to prevent loosening of the clamps, use of an antivibratory fastener, such as a nylon-locking nut, is also recommended.

### 3.04 Outdoors Exposed Piping:

- A. All outdoor exposed piping shall be painted with two coats of WB Armaflex Finish. Prior to applying the Finish, the insulation shall be wiped clean with denatured alcohol. The Finish shall not be tinted.
- B. All outdoor exposed piping shall have the seams located on the lower half of the pipe.
- C. Contact Armacell for alternate products.

### 3.05 Piping Insulation Thickness Schedule:

**NOTE** – This Armaflex insulation wall thickness schedule is based upon Armacell NORMAL Design Conditions of 85°F and 70% RH. Deviations from these design conditions may change the Armaflex Insulation thickness requirements. Consult local energy code requirements for minimum insulation thickness.

#### 3.05.1 AP Armaflex and NH Armaflex Insulations

Piping System	Up to 2"	Over 2" to 4"	Over 4" to 6"	Over 6"
<b>Plumbing:</b>				
Cold Water	1/2"	1/2"	1/2"	3/4"
Hot Water	1/2"	1/2"	3/4"	3/4"
Heating Hot Water	3/4"	3/4"	1"	1"
<b>Drains:</b>				
Roof Drains	1/2"	1/2"	1/2"	3/4"
Storm Drains	1/2"	1/2"	3/4"	3/4"
<b>Chilled Water:</b>				
Chilled Water	1/2"	3/4"	1"	1"
Condensate Drain	1/2"	3/4"	–	–
<b>Refrigeration:</b>				
Above 25°F	3/4"	3/4"	1"	1"
11°F to 25°F	1"	1"	1"	1-1/4"
-10°F to 10°F	1"	1-1/4"	1-1/4"	1-1/2"
Below -10°F	1-1/4"	1-1/4"	1-1/2"	1-1/2"

**3.05.2 HT Armaflex Insulation**

Piping System	Up to 2"	Over 2" to 4"	Over 4" to 6"	Over 6"
<b>Plumbing:</b>				
Cold Water	1/2"	1/2"	1/2"	3/4"
Hot Water	1/2"	1/2"	3/4"	3/4"
Heating Hot Water	3/4"	3/4"	1"	1"
<b>Drains:</b>				
Roof Drains	1/2"	1/2"	1/2"	3/4"
Storm Drains	1/2"	1/2"	3/4"	3/4"
<b>Chilled Water:</b>				
Chilled Water	3/4"	1"	1"	1"
Condensate Drain	1/2"	3/4"	–	–
<b>Refrigeration:</b>				
Above 25°F	3/4"	1"	1"	1"
11°F to 25°F	1"	1"	1-1/4"	1-1/4"
-10°F to 10°F	1"	1-1/4"	1-1/2"	1-1/2"
Below -10°F	1-1/4"	1-1/2"	1-3/4"	1-3/4"

**3.06 Square and Rectangular Ductwork:**

- A. The ductwork must be sloped to prevent "ponding" of water. The recommendation is at least a 2° angle to the outer side.
- B. Armaflex Sheet Insulation shall be adhered directly to clean, oil-free surfaces with a full coverage of Armaflex 520 or 520 BLV Adhesive. Armaflex HT 625 Adhesive shall be used with HT Armaflex. AP Armaflex SA shall be adhered directly to clean, oil-free surfaces.
- C. The duct insulation shall be constructed from the bottom up, with the top insulation sized to extend over the side insulation. This will form a watershed.
- D. Butt-edge seams shall be adhered using Armaflex 520, 520 BLV, or HT 625 Adhesive by the compression fit method to allow for expansion/contraction. Leave a 1/2"-wide uncoated border at the butt-edge seams on the duct surface and the insulation surface. Overlap the insulation 1/4" at the butt-edges and compress the edges into place. Apply Armaflex 520, 520 BLV, or HT 625 Adhesive to the butt-edges of the insulation.
- E. Standing metal duct seams shall be insulated with the same insulation thickness as installed on the duct surface. Seams may be covered using strips of Armaflex Sheet Insulation or half sections of tubular pipe insulation with miter-cut ends. Standing seams shall be adhered using Armaflex 520, 520 BLV, or HT 625 Adhesive.
- F. Insulation seams shall be staggered when applying multiple layers of insulation.

**3.07 Round Ductwork:**

- A. AP Armaflex Sheet and Roll Insulation, HT Armaflex Roll Insulation, or NH Armaflex Sheet and Roll Insulation shall be used on all round ductwork. Insulation shall be wrapped not stretched around the duct. On ductwork larger than 12" in diameter, the insulation shall be adhered to the duct

surface on the lower one third. On ductwork greater than 24" in diameter, the insulation shall be completely adhered to the duct surface. Longitudinal seams shall be located on the lower half of any round ductwork:

- B. Butt-edge seams shall be adhered using Armaflex 520, 520 BLV, or HT 625 Adhesive by the compression fit method to allow for expansion/contraction. Leave a 1/2" wide uncoated border at the butt-edge seams on the duct surface and the insulation surface. Overlap the insulation 1/4" at the butt-edges and compress the edges into place. Apply Armaflex 520, 520 BLV, or HT 625 Adhesive to the butt-edges of the insulation.
- C. Insulation seams shall be staggered when applying multiple layers of insulation.

### **3.08 Exposed Outdoor Duct:**

- A. All outdoor exposed ductwork shall be finished using one of the following applications: For all the application methods described below it is very important that the exterior horizontal surfaces shall be sloped to prevent ponding on the surface of the coated insulation. If the substrate is not sloped make the necessary adjustments to provide for a slope. DO NOT compromise the Armaflex insulation thickness to achieve the necessary slope.

#### **3.08.1 ArmaTuff – Laminated Armaflex Sheet and Roll Insulations**

ArmaTuff laminated Armaflex sheet and roll insulations may be used for insulating exterior applications such as duct, tanks, vessels and large pipes. Refer to section 3.06 for further installation details.

ArmaTuff 25 is a laminate of white thermoplastic rubber (TPR) membrane on Armaflex insulations, which offers durability and resistance to weathering, ultraviolet, acid rain and chemicals. The membrane is 0.022 inches (22 mils) thick. The seams must be installed in compression and sealed with Armaflex 520 or 520 BLV contact adhesive. Cover the seams using ArmaTuff 25 Seal Tape.

ArmaTuff White is a white laminate composite layer of coated foil and polymer, which offers durability and resistance to weathering, ultraviolet, acid rain and chemicals. The composite is 0.005 inches (5 mils) thick. The seams must be installed in compression and sealed with Armaflex 520 or 520 BLV contact adhesive. Cover the seams using ArmaTuff White Seal Tape.

ArmaTuff Silver is a silver metal foil composite which offers durability and resistance to weathering and ultraviolet radiation. The composite is 0.005 inches (5 mils) thick. The seams must be installed in compression and sealed with Armaflex 520 or 520 BLV contact adhesive. Cover the seams using ArmaTuff Silver Seal Tape.

#### **3.08.2 WB Armaflex Finish**

All outdoor ductwork shall be finished with a minimum requirement of two coats of WB Armaflex Finish.

- 1. Rectangular ductwork
  - a. The surface of the insulation must be clean and dry.
  - b. Apply first coat of WB Armaflex Finish at a rate of 400 square feet per gallon.
  - c. Allow to dry at least four hours.
  - d. Apply second coat at a rate of 400 square feet per gallon.

**DO NOT TINT FINISH!**

### **3.08.3 WB Armaflex Finish With 10 x 10 Leno Weave Glass Mesh**

All outdoor ductwork shall be finished with a minimum requirement of two coats of WB Armaflex Finish. For additional durability, a 10 x 10 Leno weave glass cloth can be applied over the insulation:

#### **1. Rectangular ductwork**

- a. The surface of the insulation must be clean and dry.
- b. Allow adhesive seams on the insulation to set for two hours.
- c. Application of 10 x 10 Leno weave glass mesh.
  1. Apply thin uniform coat of Childers CHIL-SPRAY® WB CP-56 Adhesive. Allow to become tacky, and apply 10 x 10 Leno weave glass mesh. (CP-56 Adhesive may take up to 20 minutes to become tacky.)
  2. As an alternate, use pre-adhesived 10 x 10 Leno glass mesh.
- d. Allow adhesive and mesh to dry four hours.
- e. Apply WB Armaflex Finish over the mesh at a rate of less than 400 square feet per gallon. Allow to dry four hours.
- f. Apply the second coat of WB Armaflex Finish at a rate of less than 400 square feet per gallon.

**DO NOT TINT FINISH!**

#### **2. Round ductwork**

- a. The surface of the insulation must be clean and dry.
- b. Allow adhesive seams on the insulation to set for two hours.
- c. Application of 10 x 10 Leno weave glass mesh.
  1. Apply thin uniform coat of Childers CHIL-SPRAY® WB CP-56 Adhesive. Allow to become tacky, and apply 10 x 10 Leno weave glass mesh. (CP-56 Adhesive may take up to 20 minutes to become tacky.)
  2. As an alternate, use pre-adhesived 10 x 10 Leno glass mesh.
- d. Allow adhesive and mesh to dry four hours.
- e. Apply WB Armaflex Finish over mesh at a rate of less than 400 square feet per gallon. Allow to dry four hours.
- f. Allow a three-inch gap in the glass mesh at the bottom, unexposed portion of the duct to allow for thermal expansion/contraction.
- g. Apply the second coat of WB Armaflex Finish a rate of not more than 400 square feet per gallon.

**DO NOT TINT FINISH!**

### **3.08.4 Mastec System**

#### **1. Round or rectangular ductwork**

There are a number of acceptable mastec products including the following:

Childers AK-CRYL™ CP-9  
Childers AK-CRYL™ CP-10  
Childers AK-CRYL™ CP-35

Epox Manufacturing Corp Epox 510  
Mon-Eco Industries MEI 55-40  
Vimasco WC 5  
Vimasco WC 7

Please consult the mastic manufacturer for any additional recommendations.

- a. The surface of the insulation must be clean and dry.
- b. Wipe the surface of the Armaflex Insulation with a clean cloth.
- c. Apply a tack coat of mastic with a uniform thickness at a rate of 50 square feet/gallon by trowel, glove, large brush, or spray.

**DO NOT THIN MASTIC!**

- d. Blend 10 x 10 Leno weave glass mesh into the first application of mastic, making sure to overlap the seams of the glass cloth by 2 inches.
- e. Apply a finish coat within one hour after the tack coat at a rate of 50 square feet/gallon. The mastic will dry to the touch in two hours, but complete drying takes 24 to 36 hours.

**3.09 Ventilation Ductwork Insulation Thickness Schedule:**

**NOTE** - This Armaflex insulation wall thickness schedule is based upon Armacell NORMAL Design Conditions of 85°F and 70% RH. Deviations from these design conditions may change the Armaflex Insulation thickness requirements. Consult local energy code requirements for minimum insulation thickness.

**Duct Systems:**

**Supply and Return, Outside Air or Exhaust Air:**

System Temperature	AP Armaflex Thickness	HT Armaflex Thickness	NH Armaflex Thickness
Below 0°F	2"	2"	2"
0°F to 20°F	1-1/2"	1-1/2"	1-1/2"
21°F to 40°F	1"	1"	1"
41°F to 55°F	3/4"	3/4"	3/4"
56°F to 100°F	1/2"	1/2"	1/2"
101°F to 120°F	3/4"	3/4"	3/4"
121°F to 140°F	1"	1"	1"
141°F to 160°F	1-1/2"	1-1/2"	1-1/2"
161°F to 180°F	2"	2"	2"
181°F to 220°F	2"	2-1/2"	2"
221°F to 300°F	-	3"	-



### 3.10 Ventilation Equipment Insulation:

- A. Armaflex Sheet Insulation shall be adhered directly to clean, oil-free surfaces with a full coverage of Armaflex 520, 520 BLV, or HT 625 Adhesive. AP Armaflex SA shall be adhered directly to clean, oil-free surfaces.
- B. All seams and butt-joints shall be adhered and sealed with Armaflex 520, 520 BLV, or HT 625 Adhesive.
- C. On cold surfaces: All exposed end cuts of insulation shall be coated with Armaflex 520, 520 BLV, or HT 625 Adhesive.
- D. Seams shall be staggered when applying multiple layers of insulation.

### 3.11 Ventilation Equipment Insulation Thickness Schedule:

**NOTE** – This Armaflex insulation wall thickness schedule is based upon Armacell NORMAL Design Conditions of 85°F and 70% RH. Deviations from these design conditions may change the Armaflex Insulation thickness requirements. Consult local energy code requirements for minimum insulation thickness.

System Temperature	AP Armaflex Thickness	HT Armaflex Thickness	NH Armaflex Thickness
Below 0°F	2"	2"	2"
0°F to 20°F	1-1/2"	1-1/2"	1-1/2"
21°F to 40°F	1"	1"	1"
41°F to 55°F	3/4"	3/4"	3/4"
56°F to 100°F	1/2"	1/2"	1/2"
101°F to 120°F	3/4"	3/4"	3/4"
121°F to 140°F	1"	1"	1"
141°F to 160°F	1-1/2"	1-1/2"	1-1/2"
161°F to 180°F	2"	2"	2"
181°F to 220°F	2"	2-1/2"	2"
221°F to 300°F	–	3"	–

Armacell provides this information as a technical service. To the extent the information is derived from sources other than Armacell, Armacell is substantially, if not wholly, relying upon the other source(s) to provide accurate information. Information provided as a result of Armacell's own technical analysis and testing is accurate to the extent of our knowledge and ability, as of date of printing, using effective standardized methods and procedures. Each user of these products, or information, should perform their own tests to determine the safety, fitness and suitability of the products, or combination of products, for any foreseeable purposes, applications and uses by the user and by any third party to which the user may convey the products. Since Armacell cannot control the end use of this product, Armacell does not guarantee that the user will obtain the same results as published in this document. The data and information are provided as a technical service and are subject to change without notice.

BEST AVAILABLE COPY



999	028	12	04	NA	NA
-----	-----	----	----	----	----

© 2004 Armacell LLC

Printed in United States of America